

TEST RESULTS						
Contaminant (Unit Measurement)	MCLG	Meets Safe Drinking Water Act Standards	MCL	Level Detected	Range	Likely Source of Contamination
<b>Disinfection Byproducts</b>						
HAA5 (ppb)	60	Yes	60	3	0.0-3.0	
TTHM(ppb)	0	Yes	80	12.0	0.7-12.0	Byproduct of drinking water chlorination
<b>Inorganic Contaminants</b>						
Arsenic (ppb)	n/a	Yes	10	2	1—2	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	2	Yes	2	0.045	.011-.045	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Cadmium (ppb)	5	Yes	5	.1	nd-.1	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	Yes	100	4	3-4	Discharge from steel and pulp mills; Erosion of natural deposits
Copper (ppm)	1.3	Yes	AL = 1.3	0.19	0 of 20	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Fluoride (ppm)	4	Yes	4	0.1	0.1	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Lead (ppb)	0	Yes	AL = 15	15	2 of 20	Corrosion of household plumbing systems, Erosion of natural deposits
Nickel (ppb)	n/a	Yes	100	4.1	2.5-4.1	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.
Nitrate (NO3-N) (ppm)	10	Yes	10	4.0	.20-4.0	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	n/a	Yes	n/a	6.2	1.7-6.2	n/a
Selenium (ppb)	50	Yes	50	3	2-3	Discharge from petroleum and metal refineries; erosion of natural deposits; Discharge from mines.
<b>Unregulated Contaminants</b>						
Bromodichloromethane (ppb)	n/a	Yes	n/a	3.9	.24-3.9	n/a
Bromoform (ppb)	n/a	Yes	n/a	.21	0-.21	n/a
Chloroform (ppb)	n/a	Yes	n/a	6.5	.21-6.5	n/a
Dibromochloromethane (ppb)	n/a	Yes	n/a	1.6	.21-1.6	n/a
<b>Volatile Organic Contaminants</b>						
Ethylbenzene(ppb)	700	Yes	700	.3	nd-1.0	Discharge from petroleum refineries
Toluene(ppm)	1	Yes	1	.0012	nd-.0047	Discharge from petroleum factories.
Xylenes(ppm)	10	Yes	10	.0014	nd-.0054	Discharge from petroleum factories; Discharge from chemical factories

### Number of Contaminants Required to be Tested

Here are the number of contaminants that were required to be tested in the last five years. This report may contain up to five years worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown. If testing is done less frequently, the results shown are from the past five years.

<b>Contaminant Group</b>	<b># of Contaminants</b>
Disinfection Byproducts	2
Inorganic Contaminants	16
Microbiological Contaminants	2
Radioactive Contaminants	3
Synthetic Organic Contaminants including Pesticides and Herbicides	25
Unregulated Contaminants	4
Volatile Organic Contaminants	20