

City of Shawano

2023 Annual Drinking Water Quality Report

This is our twenty third Annual Drinking Water Quality Report. We want you to be informed about the water we deliver, and you use every day. This report contains important information about your drinking water. Have someone translate it for you or talk to someone who understands it. The Consumer Confidence Report is available to the public upon request. We are dedicated to providing you, our customer, with safe, clean and high-quality drinking water. We want to share with you the results of our efforts.

If you have any questions about this report or concerning your water utility, please contact the Director of Public Works at (715) 526-3512. To learn more, please attend any of our regularly scheduled Field Committee meetings. The meetings are usually held the last Tuesday of each month at 8:30 a.m. at City Hall, 127 S. Sawyer St., Shawano.

The Wisconsin Department of Natural Resources website is also a great source of information on drinking water. The DNR's "Drinking Water and Groundwater" website can be accessed at <http://dnr.wi.gov/org/water/dwg>.

Where Our Water Comes From

The City of Shawano Public Works Department owns and operates the water supply and distribution system for most of the City of Shawano. The area along Green Bay Street east of Waukechon St. is served by Shawano Lake Sanitary District. The Shawano water system presently consists of four active ground water wells constructed in the Elk Mound Group of the Cambrian Sandstone, a 500,000-gallon elevated storage tank, a 2-million-gallon ground storage reservoir and the water distribution system. The distribution system consists of approximately 58 miles of water main. The system pumps 1.3 million gallons of water per day from our four wells. The employees at the Shawano Public Works Department work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Educational Information

Sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, Industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

DPW Tests for Water Quality

The DPW staff monitors many different contaminants in your drinking water according to Federal and State Laws. In addition, we also monitor on a weekly basis for potential harmful bacteria. Out of all the constituents that we are required to test, none were in violation.

The EPA has determined that your water is safe at these levels. We are proud to report that the water provided by the City of Shawano meets or exceeds established Federal and State water quality standards.

Current Tests Results

Here are the number of contaminants that were required to be tested in the last five years. This report may contain up to five years' worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown. If testing is done less frequently, the results shown are from the past five years.

Contaminant Group	# of Contaminants
Disinfection Byproducts	2
Inorganic Contaminants	10
Radioactive Contaminants	4
Synthetic Organic Contaminants including Pesticides and Herbicides	1
Unregulated Contaminants	2
Contaminants with a Recommended Health Advisory Level	7

The following table shows the current detection results of our monitoring. The state requires monitoring certain constituents less than once a year because concentrations of these constituents are not expected to vary significantly from year to year.

CURRENT TEST RESULTS

Microbiological Contaminants You do not need this Microbiological statement if there are No violations (removed for 2023)

Contaminant	MCL	MCLG	Count of Positives	Violation	Typical Source of Contamination
E. Coli	Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli	0		NO	Human and animal fecal waste

Contaminant (Unit Measurement)	MCLG	Violation	MCL	Level Detected	Range	Likely Source of Contamination
-----------------------------------	------	-----------	-----	-------------------	-------	--------------------------------

Disinfection Byproducts

HAA5 (ppb) site D-6	60	No	60	3	3	Byproduct of drinking water chlorination
TTHM (ppb) site D-6	0	No	80	9.1	9.1	Byproduct of drinking water chlorination

Inorganic Contaminants

Arsenic (ppb)	n/a	No	10	2	0 - 2	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppb)	2	No	2	0.087	0.015 – 0.087	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	No	100	ND	1.1-3.8	Discharge from steel and pulp mills; Erosion of natural deposits
Copper (ppm)	1.3	No	AL = 1.3	0.1500	0 of 20	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Fluoride (ppm)	4	No	4	0.1	.01 – 0.1	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Lead (ppb)	0	No	AL = 15	3.70	0 of 20	Corrosion of household plumbing systems; Erosion of natural deposits
Nickel (ppb)	n/a	No	100	4.2000	1.8000 – 4.2000	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.
Nitrate (NO3-N) (ppm)	10	No	10	4.6	1.80 – 4.60	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	n/a	No	n/a	13	8.20 - 13.00	n/a
Selenium (ppb)	50	No	50	1	0 - 1	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines (sample 04/21/2020)

Unregulated Contaminants

Metolachlor (DUAL) (ppb)	n/a	No	n/a	0.01	0.01	n/a (sample date 08/04/2020)
--------------------------	-----	----	-----	------	------	---------------------------------------

Synthetic Organic Contaminants including Pesticides and Herbicides

Atrazine (ppb)	3	No	3	0	0.00 – 0.00	Runoff from herbicide used on row crops
----------------	---	----	---	---	-------------	---

Radioactive Contaminants

Gross Alpha, Excl. R&U (pCi/l)	0	No	15	3	0.0-3.0	Erosion of natural deposits (Sample date 04/21/2020)
Radium, (226,228) (pCi/l)	0	No	5	0.4	0.0-0.4	Erosion of natural deposits (sample date 04/21/2020)
Gross Alpha, Incl. R&U (n/a)	n/a	No	n/a	3.5	0.0-3.5	Erosion of natural deposits (sample date 04/21/2020)
Combined Uranium (ug/l)	30	No	0	1.0	0.6-1.0	Erosion of natural deposits (sample date 04/21/2020)

Contaminants with a Public Health Groundwater Standard, Health Advisory Level, or a Secondary Maximum Contaminant Level

Contaminant (units)	Site	SMCL (ppm)	PHG or HAL (ppm)	Level Found	Range	Sample date if prior to 2023	Typical source of Contaminant
Chloride (ppm)		250		43.0	13.00 – 43.00	10/06/2020	Runoff/Leaching from natural deposits, road salt, water softeners
Manganese (ppm)		0.05	0.3	0.00	0.00 – 0.00	10/06/2020	Leaching from natural deposits
Sulfate (ppm)		250		25.00	19.00 – 25.00	09/23/2020	Leaching from natural deposits, Industrial waste

PFAS Contaminants with a Recommended Health Advisory Level

Perfluoroalkyl and polyfluoroalkyl substances (PFAS) are a large group of humans made chemicals that have been used in industry and consumer products worldwide since the 1950's. The following tables list the contaminants which were detected in our water and that have a Recommended Public Health Groundwater Standard (RPHGS) or Health Advisory Level (HAL). There are no violations for the detections of contaminants that exceed the RPHGS or HAL. The RPHGS are levels at which concentrations of the contaminant present a health risk and are based on guidance provided by the Wisconsin Department of Health Services.

Typical Contaminant	Source of	Drinking water is one way that people can be exposed to PFAS. In Wisconsin, two-thirds of people use groundwater as their drinking water source. PFAS can get in groundwater from places that make or use PFAS and release from consumer products in landfills.			
Contaminant (units)	Site	RPHGS or HAL (PPT)	Level Found	Range	Sample date (if prior to 2023)
PFBS (ppt)		450000	0.45	0.00 – 0.45	
PFHXS (ppt)		40	0.33	0.00 – 0.33	
PFHXA (ppt)		150000	0.61	0.00 – 0.61	
PFOA (ppt)		20	1.90	0.00 – 1.90	
PFOA and PFOS total		20	1.90	0.00 – 1.90	

Definitions of Terms

In the previous tables you may have found many terms and abbreviations you were not familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

HA and HAL – HA: Health Advisory. An estimate of acceptable drinking water levels for a chemical substance based on health effects information. HAL: Health Advisory Level is a concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice. Health Advisories are determined by the US EPA.

HI – Hazard Index: A Hazard Index is used to assess the potential health impacts associated with mixtures of contaminants. Hazard Index guidance for a class of contaminants or mixture of contaminants may be determined by the US EPA or Wisconsin Department of Health Services. If a Health Index is exceeded a system may be required to post a public notice.

Maximum Contaminant Level (MCL) - Highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per billion (ppb) or Micrograms per liter - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per trillion (ppt) or Nanograms per liter – One ppt is the equivalent of one drop of impurity in 500,000 barrels of water or traveling 6 inches out of a 93-million-mile journey.

PHGS – Public Health Groundwater Standards are found in NR 140 Groundwater Quality. The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.

RPHGS – Recommended Public Health Groundwater Standards: Groundwater standards proposed by the Wisconsin Department of Health Services. The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.

SMCL – Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.

Picocuries per liter (pCi/L) - A measure of the radioactivity in water.

Total Coliform Rule (TCR) - A measure of testing that has been performed since the early 20th century.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Additional Health Information

Inorganic Contaminants

Arsenic. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.

Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

Chromium. Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor. Drinking Softened water may raise your exposure to higher levels of copper.

Fluoride. Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. **Pregnant women, infants and young children are typically more vulnerable to lead in drinking water than the general population.** It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. **When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking** If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. All potential sources of lead in the household should be identified and removed, replaced or reduced. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791) or from the EPA's web site at www.epa.gov/safewater/lead.

Nickel. Nickel is a metallic element with a silvery-white shiny appearance and occurs extensively in the earth's crust and core. It occurs naturally in soil and water.

Nitrate. Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than 6 months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider. Females who are or may become pregnant should not consume water with nitrate concentrations that exceed 10 ppm. There is some evidence of an association between exposure to high nitrate levels in drinking water during the first weeks of pregnancy and certain birth defects. The Wisconsin Department of Health Services recommends people of all ages avoid long-term consumption of water that has nitrate levels greater than 10 milligrams per liter (mg/L).

Sodium. Is a chemical element which does not occur in nature and must be prepared from compounds.

Selenium. It is a mineral found in the soil. It naturally appears in water and some foods.

The **Total Coliform** Rule requires water systems to meet a stricter limit for coliform bacteria. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are performed to determine if harmful bacteria are also present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television or radio. DPW treats the water with chlorine as a disinfectant. We are not required to add chlorine but do so as a precautionary measure.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of developing the described health effect.

Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hot line (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (1-800-426-4791) or from their web site at www.epa.gov/safewater/hfacts.html.

As you can see from the table, **our system has no violations.** We're proud that your drinking water meets or exceeds all Federal and State Requirements

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or manmade. Constituents can be microbes, organic or inorganic chemicals, or radioactive materials.

The fact that our system is based on deep well water reduces the risk of certain contaminants associated with surface water systems, such as cryptosporidium.

The SCADA systems controls the wells, reservoir, and water tower. The SCADA system provides alarms when the tower level is too high or low and when there is a power outage that requires the operators to use standby generators.

The city is committed to providing quality water to the residents of Shawano and from time to time extensive maintenance must be completed to maintain our high level of quality. If you have any questions regarding this notice, please contact the City of Shawano Water Operation Department at (715) 526-3512.

Other Compliance

Projects of note for 2022

All of the cities known lead water services were removed prior to September 30 2022. The City of Shawano has a Lead-free status. Also, the city's 2 million gallon above ground storage tank was upgraded with significant maintenance and equipment.

What's new for 2023

Water main replacements that are coordinated with 2023 street reconstruction projects are in the following areas: 4, 5, 6, and 700 blocks of S. Weed St., 600 block of W. Danks, 6 and 700 block of W. Pine St., and 600 block of S. River St.

All wells have been maintained based on the DNR recommended schedule.

The DPW provides clean safe water to all its customers. We are also responsible for inspecting the plumbing in your building to make sure that there is no possibility that it could contaminate the city water supply. Cross-Connection inspections will be done at approximately 200 businesses and 340 residences during 2023. If your home or business is to be inspected this year you will be notified by mail to schedule an inspection. If you would like to have your home or business inspected for a lead water service, please call DPW to schedule that inspection.

City of Shawano — Public Works Department

2905 E. Richmond St., Shawano WI 54166

Phone: (715) 526-3512, Fax: (715) 526-3519

Email: dpwstaff@cityofshawano.com Website: www.cityofshawano.com

Hours: Monday—Friday: 7:00 a.m.—3:00 p.m.

